

Kitemark™ Certificate

This is to certify that:

Shield Fire Safety & Security Ltd
Unit 3
Endeavour Drive
Basildon
SS14 3WF
United Kingdom

Holds Certificate Number:

KM 638120

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Chris Lewis - Certification Director, Product Certification

First Issued: 2015-11-11
Latest Issue: 2020-09-24

Effective Date: 2020-09-24
Expiry Date: 2022-05-22

Page: 1 of 2



003

...making excellence a habit.™

Kitemark™ Certificate

No. KM 638120

| Model No. | Description |
|-----------|--|
| SDP1 | 1 kg ABC powder, stored pressure. Fire rating 8A & 34B |
| SDP2 | 2 kg ABC powder, stored pressure. Fire rating 13A & 70B |
| SDP4 | 4 kg ABC powder, stored pressure. Fire rating 21A & 113B |
| SDP6 | 6 kg ABC powder, stored pressure. Fire rating 34A & 183B |
| SDP9 | 9 kg ABC powder, stored pressure. Fire rating 43A & 233B |
| SDP12 | 12 kg ABC powder, stored pressure. Fire rating 55A & 233B |
| SDF6 | 6 litre foam, stored pressure. Fire rating 21A & 144B |
| SDFI6 | 6 litre foam, stored pressure. Fire rating 21A & 144B |
| SDF9 | 9 litre foam, stored pressure. Fire rating 21A & 183B |
| SDFI9 | 9 litre foam, stored pressure. Fire rating 21A & 183B |
| SDW6 | 6 litre water spray, stored pressure. Fire rating 13A |
| SDWS6 | 6 litre water jet, stored pressure. Fire rating 13A |
| SDWSI6 | 6 litre water jet, stored pressure. Fire rating 13A |
| SDW9 | 9 litre water spray, stored pressure. Fire rating 21A |
| SDWS9 | 9 litre water jet, stored pressure. Fire rating 13A |
| SDWSI9 | 9 litre water jet, stored pressure. Fire rating 13A |
| SDC2 | 2 kg carbon dioxide (steel body). Fire rating 34B |
| SDCS2 | 2 kg carbon dioxide (steel body). Fire rating 34B |
| SDCZ2 | 2 kg carbon dioxide (steel body). Fire rating 55B |
| SDC2A | 2 kg carbon dioxide (aluminium body). Fire rating 55B |
| SDC5 | 5 kg carbon dioxide (steel body). Fire rating 55B |
| SDC5A | 5 kg carbon dioxide (aluminium body). Fire rating 55B |
| SDKE3 | 3 litre wet chemical, stored pressure. Fire rating 8A & 25F |
| SDKE6 | 6 litre wet chemical, stored pressure. Fire rating 13A & 75F |

All the above products are certified to BS EN 3-7:2004+A1:2007.

First Issued: 2015-11-11
Latest Issue: 2020-09-24

Effective Date: 2020-09-24
Expiry Date: 2022-05-22

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.