

Model SD-OSY200FF-D

Product Description

Resilient Seated Gate Valves. 2 through 24 in. NPS. Valves have a rated working pressure of 200 psi (2070 kPa). Available with the following end connections.

Product Specification

Model No	Valve Size		End Connection
	in	(mm)	
SD-OSY200FF-D	2, 2 1/2, 3, 4, 6, 8, 10, 12, 14, 16, 18, 20, 24	(50, 65, 80, 100, 150, 200, 250, 300, 350, 400, 450, 500, 600)	Flange x Flange

Details

Category	Gate Valves, Outside Screw and Yoke
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Shield Fire Safety and Security Ltd
 Unit 3 Endeavor Drive, Basildon, Essex, SS14
 3WF, United Kingdom
<http://www.shieldglobal.com>

Model SD-OSY300FF-D

Product Description

Resilient Seated Gate Valves. 2 through 12 in. NPS. Valves have a rated working pressure of 300 psi (2070 kPa). Available with the following end connections.

Product Specification

Model No	Valve Size		End Connection
	in	(mm)	
SD-OSY300FF-D	2, 2 1/2, 3, 4, 6, 8, 10, 12	(50, 65, 80, 100, 150, 200, 250, 300)	Flange x Flange (ANSI, BS, EN, JIS)

Details

Category	Gate Valves, Outside Screw and Yoke
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Shield Fire Safety and Security Ltd
 Unit 3 Endeavor Drive, Basildon, Essex, SS14 3WF, United Kingdom
<http://www.shieldglobal.com>

Model SD-OSY300FG-D

Product Description

Resilient Seated Gate Valves. 2 through 12 in. NPS. Valves have a rated working pressure of 300 psi (2070 kPa). Available with the following end connections.

Product Specification

Model No	Valve Size		End Connection
	in	(mm)	
SD-OSY300FG-D	2, 2 1/2, 3, 4, 6, 8, 10, 12	(50, 65, 80, 100, 150, 200, 250, 300)	Groove x Flange (AWWA C606 x ASME B16.1)

Details

Category	Gate Valves, Outside Screw and Yoke
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Shield Fire Safety and Security Ltd
 Unit 3 Endeavor Drive, Basildon, Essex, SS14
 3WF, United Kingdom
<http://www.shieldglobal.com>